NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) AND SOIL EROSION AND SEDIMENTATION CONTROL (SESC)

ClearForm

INSPECTION REPORT

FILE 108

Completed form to
Project Files
cc: C & T Geotechnical Services

CONTROL SECTION	JOB NUMBER	ROUTE	REPORT NUMBER	DATE

RESIDENT/DELIVERY ENGINEER OR MAINTENANCE COORDINATOR	SESC CERTIFICATE NO.	NPDES CERTIFIED STORM WATER OPERATOR NO.

INSPECTOR NAME (Please print)	INSPECTOR (Signature)

AMOUNT, TYPE & DATE OF LAST PRECIPITATION	DATE OF LAST INSPECTION

CONTRACTOR	

LOCATION/ STATION	TYPE OF CONTROL	INSTALLATION DATE	CORRECTIVE ACTION REQUIRED (See Note 3)	NOTIFICATION DATE	COMPLETION DATE

REMARKS (Continue on back)

NOTES

1. Inspectors must have valid certification for both SESC and NPDES.
2. Until the Notice of Termination is submitted, site shall be inspected every 7 days and within 24 hours after every precipitation event resulting in discharge from the right of way.
3. Corrective action shall be made within 24 hours if sedimentation has occurred into a watercourse or public safety may be compromised. Otherwise corrective action shall be made within 5 calendar days.

SKETCHES

REMARKS